

Swissgrid Ltd Bleichemattstrasse 31 P.O. Box 5001 Aarau Switzerland

T +41 58 580 21 11 info@swissgrid.ch www.swissgrid.ch

Methodology for determining the NTC at the border CH-DE for the Day-Ahead-auction

Effective 1 May 2020

Date 11 March 2020 Author Swissgrid Ltd



Contents

| 1 | introduction and context | 3 |
|------|--|---|
| 2 | Abbreviations | 3 |
| 3 | Capacity determination process | 3 |
| 4 | Capacity calculation methodology | 4 |
| 5 | Critical Network Elements, Operational Security Limits, Contingencies | 4 |
| 6 | Remedial Actions | 5 |
| 7 | Generation Shift Key Methodology | 5 |
| 8 | Reliability Margin Methodology | 5 |
| 9 | Backup-Procedure | 6 |
| 10 | Transparency | 6 |
| 11 | Annex | 7 |
| 11.1 | Overview NTC CH-DE determination process | 7 |
| 11.2 | Generator Shift Key Methodologies | 7 |
| 11.3 | Determination of the Critical Network Elements relevant for the Capacity Calculation | 8 |



1 Introduction and context

This document describes the methodology, that Swissgrid uses to determine the NTC CH-DE for the Day-Ahead-auction starting in summer 2020. The final NTC CH-DE results from the minimum of the Swiss proposal and the counterproposal coming from the German transmission system operators.

2 Abbreviations

ATSO Adjacent or neighbouring TSO

L Loading of a network element

E Exchange

CNEC Critical Network Element and Contingency

NTC Net Transfer Capacity

S Sensitivity

3 Capacity determination process

- Swissgrid determines the NTC CH-DE for the Day-Ahead-auction based on scenarios on a daily basis. A scenario is a situation in the grid that consists of several parameters, that are used as a basis in the calculation process. The whole process can be found in Annex 11.1.
- 2. The parameters that characterize a scenario are the following:
 - a. Outages of nuclear power plants
 - b. Outages of grid elements
 - c. Anticipated trading scenario
- The anticipated trading scenario consists of assumptions about the expected trading directions over the borders FR-CH, DE-CH, AT-CH and CH-IT. For the rest of Europa standard reference schedules are used. In this context, a full Swiss export and a transit scenario (FR→CH→DE) are considered.
- The NTC values for each scenario are calculated on demand offline by performing a loadflowanalysis based on the capacity calculation methodology that is described in chapter 4.
- 5. The selection of the relevant scenario for the target day is determined and consequently, the relevant NTC values are chosen based on the outage planning of network elements, the outage schedules of the nuclear power plants that are reported to Swissgrid and a forecast about the expected trading scenario performed by Swissgrid.
- 6. Swissgrid coordinates the NTC CH-DE with the German TSOs. The final NTC results from the minimum of the Swiss and German proposal.



4 Capacity calculation methodology

- 1. The capacity calculation is performed offline by performing a loadflow analysis based on an European merged common grid model, which represents the selected scenario.
- 2. The Swiss generation available in this common grid model is distributed equally to all Swiss generation in relation to their maximal generation limits. Nuclear power plants are excluded from these adjustments as their maximal production is considered based on the selected scenario. This pre-treatment of the common grid model is necessary in order to avoid violations on CNECs in the base case caused by a non-uniform production distribution.
- 3. During the capacity calculation, the Swiss export in the direction towards Germany is increased under consideration of remedial actions described in chapter 6. In this context, only the operational security limits of the critical network elements according to chapter 5 are considered.
- 4. The increase of the Swiss export and the German import are done based on the Generation Shift Key methodologies described in chapter 7.

5 Critical Network Elements, Operational Security Limits, Contingencies

- 1. Swissgrid ensures, that only Critical Network Element and Contingencies (CNEC) are taken into account in the capacity calculation described in chapter 4, that fulfil the following conditions:
 - a. Sensitivity of a trade of 1000 MW from Switzerland towards Germany is higher than 10%. That means that the loading of the related Critical Network Element is after the trade between CH and DE at least 10%¹ higher than before the shift.
 - b. The loading of the Critical Network Element is not caused by a single power plant (or a power plant group in case of radial lines). In such a case the problem is considered as local and structural and therefore, the NTC should not be limited by such elements.
- The list of CNECs considered in the capacity calculation are determined for each scenario.
- 3. The maximum Base Case limit for CNECs, whose violation is caused by a single power plant (or a power plant group in case of radial lines) (refer to criteria 5(1)b)) is set to 85% as long as they are sensitive towards a trade activity from Switzerland to Germany (refer to criteria 5(1)a)).
- 4. The values defined in 5(1) and 5(3) can be adjusted if required as a result of an analysis of the particular grid situation. ElCom will be informed accordingly. The market participants will receive the information on the Swissgrid website, www.swissgrid.ch.
- 5. Swissgrid ensures that the operational security limits per Critical Network Element stay within the Operational Security Limits during the Capacity Calculation. In this context the permanent admissible current is considered. This refers in general to 100% * I_{max} and is season-dependent for lines and 100% S_{max} permanently for transformers.

¹ With this sensitivity threshold of 10% Swissgrid provides a quite high amount of capacity to the market. Other European Capacity Calculation Regions only consider a threshold of 5%.



6. Swissgrid considers all Swiss Network elements as contingency cases during the capacity calculation and relevant contingencies in the grid of the ATSOs.

6 Remedial Actions

- 1. During the capacity calculation, which is described in chapter 4, Swissgrid implements non-costly Remedial Actions for increasing the NTC.
- 2. The remedial actions used during the capacity calculation are the following:
 - a. Change of topology in substations
 - b. Change of taps of Phase Shifting Transformers
- The consideration of costly Remedial Actions like Redispatch is not necessary as all elements, whose violations require in Real-Time redispatching measures are not considered in the capacity calculation (refer to chapter 5(3)).²

7 Generation Shift Key Methodology

- The Swiss Export is changed proportional to the available generators margins according to the formulas written in chapter 11.2. All Swiss generators are adapted except nuclear power plants. The production of the nuclear power plants is considered as constant as long as they are available.
- When adapting the Swiss export, the technical limits (the maximal and minimal generator limits) are considered.
- The German import is adjusted proportionally to the generator injection that is available in the grid model.

8 Reliability Margin Methodology

- Swissgrid reduces the NTC values calculated according to chapter 4 by 200 MW in order to cope with the risk that is linked with the scenario forecast.
- 2. Swissgrid reserves the right to adjust this value in dependence of the forecast quality.

²Swissgrid could as well consider these elements in the Capacity Calculation. In case these elements would require a capacity reduction, Swissgrid would consider costly redispatch measures during the calculation to reduce the loading on these elements. Finally, this would result in the same NTC result.



9 Backup-Procedure

1. In case it turns out during the NTC determination process described in chapter 3 that no calculated NTC-values are available for the expected scenario (e.g. caused by a short-term change of the outage planning), Swissgrid considers a scenario that is close to the expected scenario.

10 Transparency

 Swissgrid publishes the final NTC values on a daily basis on the ENTSO-E Transparency Portal and on the Swissgrid Website, <u>www.swissgrid.ch</u>.



11 Annex

11.1 Overview NTC CH-DE determination process

The main NTC CH-DE determination process is depicted in the following picture:




Figure 1: Description of the process

11.2 Generator Shift Key Methodologies

Switzerland:

The Swiss production is adjusted with the help of the Reserve-Methodology. In this case, the production is adjusted proportional to the available margin per generator.

An increase of the Swiss net position by ΔE , causes an adjustment of the injection per generator k as follows:

$$P_{k,new} = P_{k,old} + \Delta E \cdot \frac{P_{k,max} - P_{k,old}}{\sum_{i=1}^{n_{PP}} (P_{k,max} - P_{k,old})}$$

A decrease of the Swiss net position by ΔE , causes an adjustment of the injection per generator k as follows

$$P_{k,new} = P_{k,old} + \Delta E \cdot \frac{P_{k,min} - P_{k,old}}{\sum_{i=1}^{n_{PP}} (P_{k,min} - P_{k,old})}$$

Where:

 $P_{k,new}$ Injection of the generator k after the implementation of ΔE

 $P_{k,old}$ Injection of the generator k before the implementation of ΔE

ΔE Change of the Swiss exchange



 $P_{k,max}$ maximal generator limit of the generator k in MW

 $P_{k,min}$ minimal generator limit or maximal pumping limit of the generator k in MW

npp number of all Swiss power plants that are available for the shift

Germany

The German production is adjusted with the help of the proportional method. A change of the German net position by ΔE causes a change of the injection per generator k as follows:

$$P_{k,new} = P_{k,old} + \Delta E \cdot \frac{P_{k,old}}{\sum_{i=1}^{n_{PP}} (P_{k,old})}$$

Where:

 $P_{k,new}$ Injection of the generator k after the implementation of ΔE

 $P_{k,old}$ Injection of the generator k before the implementation of ΔE

ΔE Change of the Swiss exchange

npp number of all German power plants that are available for the shift

11.3 Determination of the Critical Network Elements relevant for the Capacity Calculation

The determination of the relevant Critical Network Elements that are considered in the Capacity Calculation takes place in two steps:

- Identification of all network elements that are sensitive to a trade between Switzerland and Germany
- 2. Filtering of all Critical Network Elements whose violation is caused solely by one power plant or a group of power plants in case of radial lines

Step 1

In the first step, a sensitivity matrix is calculated by increasing the production in Switzerland and decreasing it in Germany.

All CNEC *i* are considered as sensitive on a trade of 1000 MW between CH→DE, which fulfill the following condition:

$$S_{CH \to DE.i} \ge 10\%$$

$$S_{CH \to DE,i} = L_{CH \to DE,i} - L_{Base\ Case,i}$$



Where:

L_{CH→DE,i} loading of the CNEC *i* after the redispatch between Switzerland and

Germany in %

L_{Base Case, i} loading of the CNEC *i* in Base Case in %

Step 2

From the list obtained from step 1, all CNECs are filtered, whose violation is solely caused by one power plant or by a power plant group in case of radial lines. This is checked with the help of the following calculation steps:

1. Calculation of the sensitivity per power plant *j* and CNEC *i* by implementing a redispatch of 100 MW between the power plant independent of its maximal generation limit due to the linearisation and Germany (Adjustment in Germany is based on the Generator Shifting Key). The sensitivity is then calculated as follows:

$$S_{PPj,CNECi} = \left(L_{PPj \to DE,i} - L_{Base\ Case,i}\right) \cdot \frac{P_{max,j}}{100\ MW}$$

Where:

Sppj,CNECi sensitivity of the power plant *j* on the CNEC *i* in %

 $L_{ppj \to DE,i}$ loading of the CNEC *i* after the redispatch between the power plant *j* and

Germany in %

LBase Case, i loading of the CNEC i in Base Case in %

 $P_{\text{max},j}$ maximal generator limits of the power plant j in MW

2. Finally, all CNECs coming from step 1 are deleted from the monitoring list, which fulfill the following condition. In this context, only $S_{PP\ i.CNEC\ i}$ >0 is considered:

a.
$$\frac{max(S_{PP\ j,CNEC\ i})}{\sum_{j=1}^{n_{PP}}(S_{PP\ j,CNEC\ i})} > 45\%$$